

State of Washington

102295 Water Well Report

Unique Well ID AGC-247

Washington Water Right Permit No:

Notice of Intent WE00166

(1) Owner: James=Carvalho Address: 4507 GROUSE CREEK ROA CHEWELAH WA 99109

(2) Location of Well: County STEVENS NW 1/4 NW 1/4 SEC. 12 T 31 NR 41 W

(2a) Street Address of Well:

Proposed Use DOMESTIC

(4) Type of Work NEW WELL Owner's number of well (if more than one)
Drilling Method ROTARY

(5) Dimensions Diameter of well 6 inches
Drilled 400 feet Depth of completed well 400

(6) Construction Details

Casing Installed Diameter From To
PVC 4 -200 400
WELDED 6 +2 263

Perforations [checked] Screens []
Type of Perforator Used SKILL SAW
Screen Type.
K-Pac Location.
Diam: Slot 1/4 X 8 From -380 To 400

Gravel/Filter packed [] Size of gravel/sand.
Material placed from: ft. to
Face seal used [checked] To what depth: 20 ft
Did any strata contain unusable water? []
Type of water: Depth of strata
Method of sealing strata off

(7) Pump Pump Manufacturer:
Pump Type: H.P.

(8) Water Levels
Land-surface elevation above mean sea level. ft.
Static level: 200 Date 10/8/01
Artesian Pressure: Date:
Artesian water is controlled by:

(9) Well Tests Drawdown is amount water level is lowered below static


Was a pump Test performed? []
Yield Drawdown Pumping Level Hours
Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)
Time Level Time Level Time Level
Test gal per min drawdown. after
Airtest gal/min. 4 gal per min
Artesian flow gpm [] Chemical test

(10) WELL LOG or DECOMMISSIONING PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information. Indicate all water encountered

From To Remarks: Lithology, Water Quality, Temperature

0 5 Top Soil
5 70 Clay Tan
70 250 Clay Gray Green
250 270 Clay Tan H2O @280-300
270 400 Shale Gray Green Soft



Start Date: 10/8/01 Completed 10/9/01

Well Construction Certification

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

Type or Print Name Jim McLeslie License No: 2257

Trainee Name License No:

Drilling Company: H2O Well Service, Inc.

(signed) Jim McLeslie License No: 2257
(Licensed Driller/Engineer)

Address: 582 W Hayden Ave, Hayden Lake, ID 83835

Contractor's H20WES1101DW Date:
Registration No:

The Department of Ecology does NOT Warrant the Data and/or the Information on this Well Report.